

Kaf-Tech

This product specification is written according to the Construction Specifications Institute
MasterFormat, 2018 Update.

SECTION 26 05 33

FLEXIBLE METAL CONDUIT – FMC

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions.

1.2 SUMMARY

- A. This Section includes flexible raceways for electrical wiring for commercial, industrial, MRO, and DOT applications.

1.3 REFERENCES

- A. UL 1- Standard for Flexible Metal Conduit - FMC
- B. UL 514B – Standard for Conduit, Tubing, and Cable Fittings

1.4 SUBMITTALS

- A. Product Data: For flexible raceway and fitting.
- B. Qualification Data: For testing agency.
- C. Field quality-control test reports.

1.5 QUALITY ASSURANCE

- A. Electrical equipment and materials shall be new and within one year of manufacture, complying with the latest codes and standards. No used, re-built, refurbished and/or re-manufactured electrical equipment and materials shall be furnished on this project.
- B. Testing Agency Qualifications: An independent agency, with the experience and capability to conduct the testing indicated, that is a member company of the International Electrical Testing Association or is a nationally recognized testing laboratory (NRTL) as defined by OSHA in 29 CFR 1910.7, and that is acceptable to authorities having jurisdiction.
- C. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.

- D. Flexible Raceways shall be manufactured in accordance with the applicable UL Standard referenced in 1.3 for installation in accordance with NFPA 70 (NEC)

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Deliver materials to site in unopened cartons, coils, reels or bundles as appropriate, clearly identified with manufacturer's name, Underwriter's or other approved label, grade or identifying number.

PART 2 - PRODUCTS

2.1 FLEXIBLE METAL CONDUIT

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. AFC Cable Systems, Inc.
- B. Shall be in compliance with UL 1.
- C. Conduit is used in flexible metal raceway systems for electrical power, communication cables, motor leads, listed assemblies and wire fixtures and manufactured wiring systems.
- D. Conduit shall be used only in non-wet locations as defined in NFPA 70 (NEC)

PART 3 - EXECUTION

3.1 RACEWAY APPLICATION

- A. Exposed, Not Subject to Physical Damage
- B. Concealed in Ceilings and Interior Walls and Partitions.
- C. In Ducts and Plenums
- D. Connection to Vibrating Equipment (Including Transformers and Hydraulic, Pneumatic, Electric Solenoid, or Motor-Driven Equipment)
- E. Raceways for Optical Fiber or Communications Cable in Spaces Used for Environmental Air.
- F. Minimum Raceway Size: 3/8-inch trade size.
- G. Raceway Fittings: Compatible with raceways and suitable for use and location.
 - a. Use only fittings listed for use with FMC.

3.2 PROTECTION

- A. Provide final protection and maintain conditions that ensure coatings, finishes, and cabinets are without damage or deterioration at time of Substantial Completion.